

March 13, 2023

SP 2302968:1 **Coliform Bacteria Analysis**

Customer ID : 2021676

Meadowlark Ranches Mutual Water Co.

Attn: Mike Hadley

System Number : 4200612

P.O. Box 606

Project Name : Routine Bacteriological

Santa Ynez, CA 93460-0606

Analytical Results

| ID | Sample Description | Total | Fecal | E. Coli | Units | Method | Prep | Footnote |
|----|--------------------|--------|-------|---------|-----------|----------|-----------------|----------|
| 1 | SS at White Oak | Absent | --- | Absent | A/P/100ml | SM 9223B | Colilert-P/A 18 | |

N/R Not Required

MPN Most Probable Number

A/P Absence/Presence

The samples listed above were Acceptable for both Total and Fecal Coliform

Sample Handling Information

| ID | Sample Number | System Number | Sample Type/Reason | Sampler | Employed By | Sampled |
|----|----------------|---------------|--------------------|-----------------|-------------------|------------------|
| 1 | SP 2302968-001 | 4200612 | System-Routine | Matthew Jimenez | FGL Environmental | 2023-03-01 09:35 |

Field Analysis/QA Information

| ID | Sample Description | Cl Total/Free mg/l | Temp | Analysis Started | Analysis Completed | Contact | Contacted |
|----|--------------------|--------------------|------|---------------------|----------------------|---------|-----------|
| 1 | SS at White Oak | ---/0.49 | --- | 2023-03-01 15:50 lm | 2023-03-02 12:14 cyn | N/R | |

Analyses were performed at the FGL Santa Paula Laboratory using Standard Methods 20th edition. If you have any questions regarding your results, please call. The FGL Santa Paula Laboratory is certified by California ELAP #1573 and accredited to ISO/IEC 17025:2017 by PJLA certificate #75605, Testing.

Prepared By: RRH

cc:SBCEH

Reviewed and
Approved By

Raquel R. Harvey



Digitally signed by Raquel R. Harvey
Title: Tech Director Microbiology
Date: 2023-03-13

