

# 2009 Consumer Confidence Report

Water System Name: Meadowlark Ranches MWC Report Date: June 15, 2010

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2008.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Four groundwater wells, Two are primarily used for domestic water while the remaining two serve as stand-bys.

Name & location of source(s): Wells # 1, 2 and 4 are located at the end of Indian Way near the Santa Ynez River, Well #3 is located on White Oak.

Drinking Water Source Assessment information: Completed by Environmental Health Services and is available upon request from the water company.

Time and place of regularly scheduled board meetings for public participation: \_\_\_\_\_

For more information, contact: Mike Hadley, President Phone: (805) 688-3132

## ***TERMS USED IN THIS REPORT:***

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (ug/L)

**ppt:** parts per trillion or nanograms per liter (ng/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

Microbiological Contaminants (to be completed only if there was a detection of bacteria )	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
<b>Total Coliform Bacteria</b>	(In a mo.) 0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
<b>Fecal Coliform or <i>E. coli</i></b>	(In the year) 0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

**TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 <sup>th</sup> percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
<b>Lead ppb 3/2007</b>	5	.75	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
<b>Copper ppm 3/2007</b>	5	.72	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2/2007	44	43-44	none	none	Generally found in ground & surface water
Hardness (ppm)	2/2007	410	410-410	none	none	Generally found in ground & surface water

\*Any violation of an MCL or AL is marked with an asterisk. Additional information regarding the violation is provided later in this report.

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Nitrate ppm	3/2009	ND	ND-ND	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Beta Particle Activity  pCi/L	2/2009	2.25 ± 1.50	1.75- 2.91	15	(0)	Erosion of natural deposits
Barium ppm	2/2007	0.032	0.032	1	2	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride ppm	2/2007	0.3	0.3	2.0	1	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
TTHMs (Total Trihalomethanes) ppb	11/2008	11	11	80	N/A	By-product of drinking water chlorination

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sulfate ppm	2/2007		230-235	500	N/A	Runoff/leaching from natural deposits; industrial wastes
Color Units	2/2007		5-10	15	N/A	Naturally-occurring organic materials
Total Dissolved Solids (TDS) ppm	2/2007		600-610	1000	N/A	Runoff/leaching from natural deposits
Specific Conductance µS/cm	2/2007		890-895	1600	N/A	Substances that form ions when in water; seawater influence

<b>Chloride</b>	<b>ppm</b>	<b>2/2007</b>	<b>18</b>	<b>18</b>	<b>500</b>	<b>N/A</b>	<b>Runoff/leaching from natural deposits; seawater influence</b>
<b>Total Chromium</b>	<b>ppb</b>	<b>2/2007</b>	<b>1.7</b>	<b>0-3</b>	<b>50</b>	<b>(100)</b>	<b>Discharge from steel and pulp mills and chrome plating; erosion of natural deposits</b>
<b>Nickel</b>	<b>ppb</b>	<b>2/2007</b>	<b>1.3</b>	<b>0-3</b>	<b>100</b>	<b>12</b>	<b>Erosion of natural deposits; discharge from metal factories</b>
<b>Iron</b>	<b>ppb</b>	<b>2/2007</b>	<b>47</b>	<b>0-140</b>	<b>300</b>		<b>Leaching from natural deposits; industrial wastes</b>
<b>Selenium</b>	<b>ppb</b>	<b>2/2007</b>	<b>1</b>	<b>0-3</b>	<b>50</b>	<b>(50)</b>	<b>Discharge from petroleum, glass, and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)</b>
<b>Aluminum</b>	<b>ppm</b>	<b>2/2007</b>	<b>.013</b>	<b>0-.030</b>	<b>200</b>		<b>Erosion of natural deposits; residual from some surface water treatment processes</b>

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

<b>Chemical or Constituent (and reporting units)</b>	<b>Sample Date</b>	<b>Level Detected</b>	<b>Notification Level</b>	<b>Health Effects Language</b>
<b>Boron ppm</b>	<b>2/2007</b>	<b>.240</b>	<b>1 ppm</b>	<b>The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.</b>
<b>Vanadium ppb</b>	<b>2/2007</b>	<b>3</b>	<b>50 ppb</b>	<b>The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals</b>

\*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

### Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement**

**The water system did not exceed any drinking water standards in 2009.**

**For Systems Providing Ground Water as a Source of Drinking Water**

*(Refer to page 1, "Type of water source in use" to see if your source of water is surface water or groundwater)*

**TABLE 7 - SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES**

<b>Microbiological Contaminants</b> (complete if fecal-indicator detected)	<b>Total No. of Detections</b>	<b>Sample Dates</b>	<b>MCL [MRDL ]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Source of Contaminant</b>
<i>E. coli</i>	(In the year)	NA	0	(0)	Human and animal fecal waste
Enterococci	(In the year)	NA	TT	n/a	Human and animal fecal waste
Coliphage	(In the year)	NA	TT	n/a	Human and animal fecal waste

**Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Violation of a Ground Water TT**